

**Southwest Kansas
Groundwater Management District**
2009 E. Spruce Street
Garden City, Kansas 67846-6158
(620) 275-7147 phone (620) 275-1431 fax
www.gmd3.org

September 2, 2010

Mark Renick
10502 6 Rd
Ingalls, KS 67853

RE: Flow test results

Dear Mark:


Enclosed are copies of flow test results performed over the last several months. Below are the summarized results of those tests. Copies of these tests are being sent to the Division of Water Resources for their records as well. If you have any questions, please contact us at your convenience.

Sincerely,

Chris Law
Resource Tech

Auction Tract	Field #	WR#	Quarter	S-T-R	Installed Flowmeter gpm	GMD3 Test Meter gpm	Percent Accuracy
1	77	11487	NE	25-25-30	348.6	366.1	-4.8
1	74	14870	SW	23-25-30	759.4	NA	NA
1	75	14870	SE	23-25-30	807.1	NA	NA
2	68	18249	SE	24-25-30	1236.5	1237.5	-0.08
			NC S2				
16	10	18794	S2	1-26-30	705.3	732.4	-3.7
			NC S2				
16	11	18794	S2	1-26-30	717.5	743.8	-3.5
12	7	19977	SE	36-25-30	569.2	545.9	4.3
15	8	21716	NW	1-26-30	408.5	425.8	-4.1
15	9	21716	NC	1-26-30	660.8	668.7	-1.2
10	41	23547	SE	30-25-29	390.6	NA	NA
10	42	23547	SW	30-25-29	756.8	NA	NA
10	43	23547	SE	25-25-30	804.8	844.9	-4.7
11	63	23547	NE	36-25-30	384.3	361.4	6.3
11	64	23547	NW	31-25-29	399.6	399.1	0.1
11	65	23547	NE	31-25-29	326.9	377.4	-13.4
5	44	23548	SW	25-25-30	692.2	671.5	3.1
5	45	23548	NW	25-25-30	383.7	349.8	9.7

5	46	23548	SE	26-25-30	467.8	NA	NA
5	47	23548	SW	26-25-30	481.0	446.8	7.6
6	55	23548	NW	36-25-30	397.7	412.8	-3.6
6	56	23548	NE	35-25-30	423.4	407.6	3.9
6	57	23548	NW	35-25-30	607.5	633.7	-4.1
9	60	24385	SW	36-25-30	587.4	602.1	-2.4
8	58	25234	SW	35-25-30	573.7	566.5	1.3
8	59	25234	SE	35-25-30	688.7	NA	NA
2	12	25757	NE	30-25-29	513.3	500.0	2.7
7	61	28237	NE	34-25-30	823.4	834.7	-1.4
7	62	28237	SE	34-25-30	462.3	498.7	-7.3
13	69	29083	SW	31-25-29	466.6	458.4	1.8
13	70	29083	SE	31-25-29	457.8	460.7	-0.6
14	72	29083	NE	1-26-30	530.0	536.3	-1.1
69	13	FI14	SE	13-25-31	321.4	321.6	0.0



WATER MANAGEMENT
FOR THE
SOUTHWEST

GMD3



Southwest Kansas Groundwater Management District

2009 E. Spruce Street
Garden City, Kansas 67846-6158
(620) 275-7147 phone (620) 275-1431 fax
www.gmd3.org

September 2, 2010

Mark Renick
10502 6 Rd
Ingalls, KS 67853

RE: Flow test results

Dear Mark:

Enclosed are copies of flow test results performed over the last several months. Below are the summarized results of those tests. Copies of these tests are being sent to the Division of Water Resources for their records as well. If you have any questions, please contact us at your convenience.

Sincerely,

Chris Law
Resource Tech

Auction
Tract

	Field #	WR#	Quarter	S-T-R	Installed Flowmeter gpm	GMD3 Test Meter gpm	Percent Accuracy
				25-25-			
1	77	11487	NE	30	348.6	366.1	-4.8
				23-25-			
1	74	14870	SW	30	759.4	NA	NA
				23-25-			
1	75	14870	SE	30	807.1	NA	NA
				24-25-			
2	68	18249	SE	30	1236.5	1237.5	-0.08
			NC S2	1-26-			
16	10	18794	S2	30	705.3	732.4	-3.7
			NC S2	1-26-			
16	11	18794	S2	30	717.5	743.8	-3.5
				36-25-			
12	7	19977	SE	30	569.2	545.9	4.3
				1-26-			
15	8	21716	NW	30	408.5	425.8	-4.1
				1-26-			
5	9	21716	NC	30	660.8	668.7	-1.2
				30-25-			
10	41	23547	SE	29	390.6	NA	NA

Auction
Tract

10	42	23547	SW	30-25- 29	756.8	NA	NA
10	43	23547	SE	25-25- 30	804.8	844.9	-4.7
11	63	23547	NE	36-25- 30	384.3	361.4	6.3
11	64	23547	NW	31-25- 29	399.6	399.1	0.1
11	65	23547	NE	31-25- 29	326.9	377.4	-13.4
5	44	23548	SW	25-25- 30	692.2	671.5	3.1
5	45	23548	NW	25-25- 30	383.7	349.8	9.7
5	46	23548	SE	26-25- 30	467.8	NA	NA
5	47	23548	SW	26-25- 30	481.0	446.8	7.6
6	55	23548	NW	36-25- 30	397.7	412.8	-3.6
6	56	23548	NE	35-25- 30	423.4	407.6	3.9
6	57	23548	NW	35-25- 30	607.5	633.7	-4.1
9	60	24385	SW	36-25- 30	587.4	602.1	-2.4
8	58	25234	SW	35-25- 30	573.7	566.5	1.3
8	59	25234	SE	35-25- 30	688.7	NA	NA
2	12	25757	NE	30-25- 29	513.3	500.0	2.7
7	61	28237	NE	34-25- 30	823.4	834.7	-1.4
7	62	28237	SE	34-25- 30	462.3	498.7	-7.3
13	69	29083	SW	31-25- 29	466.6	458.4	1.8
13	70	29083	SE	31-25- 29	457.8	460.7	-0.6
14	72	29083	NE	1-26- 30	530.0	536.3	-1.1
22	13	F114	SE	13-25- 31	321.4	321.6	0.0